

Attestation

Italian CAM

On 17 December 2020, Eurofins Product Testing A/S received a sample of a gasbeton with the product name:

GASBETON Dry density 300-630 kg/mc

supplied by

Ekoru Srl

The emissions were tested according to the Italian CAM Decree GU n.23 del 28-01-2017. Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, see the test report no. 392-2020-10582301_A_EN.

Evaluation of the emission test result according to Italian CAM:

- The relevant CMR compounds were not detectable after 28 days.
- The sum of VOC ("TVOC") after 28 days was below the limit of 1500 µg/m³.
- Formaldehyde after 28 days was below the limit of 60 µg/m³.
- All other parameters were below their respective limit values after 28 days.

9 April 2021



Rasmus Verdier
Analytical Service Manager



Janne Rothmann Norup
Analytical Service Manager